

CITY OF MOUNTAIN VIEW

SFUND RECORDS CTR
2807-91858

SFUND RECORDS CTR
88172030

Public Works

June 12, 1970

**Fairchild Semiconductor
401 Ellis Street
Mountain View, California 94040**

Attention: Mr. H. V. Williams, Manager Plant Engineering

Gentlemen:

RE: INDUSTRIAL WASTES

Your Drawing No. 2070 for the "Solvent Dropout and Acid Dilution Sump" to be constructed at 441 Whisman Road was delivered for review on June 9, 1970. The electrical control drawings were received on June 11.

Returned herewith is one print of Drawing No. 2070 which has been stamped "Acceptable" by the Fire Department.

- ✓ 1. We request that a waste sampling point be installed just upstream of the juncture of the new waste line with the existing building sanitary line. The riser from the underground waste line to pavement surface to be vertical with an appropriately covered terminus at the upper end.
2. No provision is indicated for manually feeding ammonia during the period when the storage tank is being refilled.
3. There is no solvent level alarm shown.
- ✓ 4. A pH recorder is required.

Please resubmit 3 sets of prints for further review.

Very truly yours,

**GEORGE L. MCPHEETERS
Water Division Engineer**

FW
CH-DPW/ADPW-OE-WDE-PWS-CBI-F: w/1 set drawings